

Fire Risk Statement

Shaneragh BESS

Ref	05577-9273317
-----	---------------

Revision History

Issue	Date	Name	Latest changes
01	20/12/2024	Martin O'Connor	First Created

Contents

1	Introduction	3
2	Project Description	4
2.1	General project information	4
2.2	Battery selection	4
3	Design Factors.....	5
3.1	RES Internal BESS safety best practice principles.....	5
3.2	Fire response strategy	5
3.3	Mitigation Measures	6
3.3.1	Equipment spacing.....	6
3.3.2	Protection systems.....	6
3.3.3	Access to battery storage enclosure.....	6
3.3.4	Location of BESS facility	6
3.3.5	Access for emergency services	6
3.3.6	Water Supply	7
4	Operational Factors	8
4.1	Hazard Identification and Mitigation Analysis	8
4.2	Hazardous Material.....	8
4.3	Emergency Response Plan.....	8
4.4	Safety Management Structure	8
4.5	Staff Competence	8
5	Conclusion	9
Appendix A	Preliminary Site Layout Drawing.....	10
Appendix B	- RES BESS safety best practice principles.....	11
Appendix C	- NFCC Recommendations Cross-Referenced to the BESS Layout and Design.....	12

1 Introduction

This document forms the Shaneragh BESS fire risk statement. The document indicates how the project has been developed to address fire risk in several ways. It contains key mitigation measures against the risk of fire ignition and propagation within the battery energy storage system (BESS) site.

Battery technology and associated understanding of fire risk is continually evolving within the industry. As such, this document sets out key principles and mitigation measures based on the current understanding of battery fire risk but does not include a detailed Fire Risk Management Plan. A detailed Fire Risk Management Plan would be developed during detailed design, following battery selection.

2 Project Description

2.1 General project information

Renewable Energy Systems Ltd (RES) is developing a BESS facility near Dromore Substation, capable of operating up to 100MW. The BESS will consist of 116 no. battery storage enclosures (BSEs), power conversion systems (PCSs), transformers, electrical infrastructure, foundations, access track, crane hardstanding, and spares storage containers. The grid connection will be via an onsite 110kV substation.

2.2 Battery selection

The proposed battery technology for the development is anticipated to be lithium iron phosphate (LFP). LFP has better thermal stability and enters thermal runaway at higher temperatures compared to some other battery chemistries. This is demonstrated by the UL 9540A test results of RES' preferred battery system which show that, at a unit level following deliberate initiation of thermal runaway:

- No flaming outside the initiating battery rack was observed.
- Surface temperatures of modules within the target battery rack adjacent to the initiating battery rack do not exceed the temperature at which thermally initiated cell venting occurs.
- Wall surface temperature rise does not exceed 97°C above ambient.
- Explosion hazards were not observed during the test.

Data from UL9540A testing can also be used to inform detailed design of the site and safety systems.

Each BSE has a footprint of approximately 6.1 x 2.4m. The exact battery form factor and capacity will be determined during detail design phase and would be documented within the detailed Fire Risk Management Plan.

3 Design Factors

3.1 RES Internal BESS safety best practice principles

Based on available standards, construction and operation experience, RES has developed internal best practice to manage the safety of battery energy storage systems. A document summary of these principles can be found in Appendix B.

3.2 Fire response strategy

It is the intention that the site would be self-sufficient during a potential battery-based fire event and would not require fire service intervention to prevent fire spread or any other significant risks to people or property. Key principles of the NFCC Grid Scale Battery Energy Storage System planning - Guidance for FRS, 2023 (“the NFCC Guidance”) are addressed through the mitigations identified within this report, as these pertain to the fire risk management strategy set out below.

The overarching fire risk management strategy would adopt the following controls:

1. Implement measures that result in a very low risk of fire ignition and any suitable environment for sustaining fire.
2. Implement measures that result in a very low risk of fire propagation and spread within a fire source (e.g. BSE).
3. Ensure fire spread between significant elements of the project is not expected, through application of design standards and use of calculations / modelling as necessary.
4. Include adequate provisions to allow the fire service to monitor a fire event, intervening only if there is a failure of the controls above.

Due to the risks associated with lithium-ion fires, transformer fires, and high-power equipment, there are significant safety benefits to minimising fire service intervention and consequential firefighter hazard exposure.

During detailed design, following battery product selection, a project specific Fire Risk Management Plan will be developed, in liaison with the Fire Service and with due consideration of the NFCC Guidance. This Fire Risk Management Plan will include:

- A fire risk appraisal that details how the fire response strategy above will be achieved, including the identification and design of any further mitigations required to achieve the strategy above.
- An emergency response plan.

3.3 Mitigation Measures

The following points define the key preliminary design mitigations against the risk of fire ignition and propagation within the BESS site.

3.3.1 Equipment spacing

The site has been developed to include adequate spacing between the battery storage enclosure (BSE) to mitigate against the risk of fire spread in the event of a fire within one BSE. The site layout aligns with applicable NFPA 855 spacing criteria as well as the spacing recommendations outlined in FM Global Property Loss Prevention Datasheet 5-33 (Interim revision July 2023). The layout allows minimum distance of 3m between batteries enclosures and any other infrastructure.

3.3.2 Protection systems

Each BSE will have a dedicated fire protection system, comprising flammable gas detection and venting, fire detection and alarm, and an automatic fire suppression system. Additionally, key battery health and environment parameters will be continuously monitored with alarms sent to a control centre. Automatic electrical disconnection will be enacted by the battery management system should operational temperature, current or voltage limits be breached. There will be levels of alarms prior to protection limits which warn the operator of proximity to safe operating limits. BSEs will be fitted with deflagration venting and explosion protection appropriate to the hazard.

3.3.3 Access to battery storage enclosure

All BSEs will be accessed via external doors only, i.e. no internal corridor to eliminate the risk of people being inside an enclosure during a fire or thermal runaway gas venting incident.

3.3.4 Location of BESS facility

The location of the facility has been selected considering the distances from existing nearby premises. There are no premises nearby site, with the nearest one to site to be more than 300m in distance. A distance of at least 23m is achieved between BSEs and the site boundary, in line with NFPA 855 (2023), and there is no existing or planned bushes or trees within 10m of any BSE.

3.3.5 Access for emergency services

The fenced BESS compound has a wide access routes through the site, allowing the fire service to access the site during an incident. In addition, two site access points have been proposed to ensure that fire services would have an alternative option for approaching site if the combination of wind direction and smoke made one direction particularly onerous.

Turning locations for emergency response vehicles are available within the site hardstanding and at the main entrance gates. See Appendix A for site layout, including multiple access routes.

Vehicular access to allow the emergency services to safely reach the development during design flood conditions has been assessed. A risk of surface water flooding has been identified at the northern entrance, however this is also the entrance most likely to be affected by smoke drift due to the prevailing winds (as

per the wind rose shown in Appendix A). Therefore in the less probable scenario of simultaneous flooding, fire and strong winds, it is most likely that only the northern access route would be affected.

3.3.6 Water Supply

It is intended that an onsite water supply would not be required to achieve the fire response strategy outlined in 3.1. However, if agreed as necessary in development of the Fire Risk Management Plan, a supply of 1,900 litres per minute for at least 2 hours in line with the NFCC Guidance could be achieved through provision of a dedicated fire water tank at the potential location identified in Appendix A.

Additionally there is a stream to the east of the site, approximately at the position of the start of the northern access road, which may provide a supplementary supply of water.

4 Operational Factors

As well as mitigations to make the site inherently safer by design and the inclusion of active and passive controls, operational mitigations will be implemented to manage fire risk. This section states the operational factors which will be considered in the detailed Fire Risk Management Plan.

4.1 Hazard Identification and Mitigation Analysis

During detailed design, project and equipment specific hazards will be identified. Actions taken to mitigate those hazards will also be identified and residual risks will be communicated as part of the emergency response plan.

4.2 Hazardous Material

Any hazardous materials stored at the BESS facility will be fully justified and detailed in the emergency response plan. This will detail the location, description, quantity and appropriate precautions.

4.3 Emergency Response Plan

The Emergency Response Plan will be developed iteratively in line with the project specific Fire Risk Management Plan. It will outline how the operator will respond to incident and accident scenarios on site including clear guidance for first responder organisations.

4.4 Safety Management Structure

The BESS safety management structure is yet to be fully defined but will include a formal top-down management structure that has the authority and responsibility to make decisions in design, procurement, construction and operation that places safety and environmental risk at forefront.

4.5 Staff Competence

The Fire Risk Management Plan will ensure that all personnel who have responsibility for safety or activities which could impact the surrounding environment are competent to discharge those responsibilities.

5 Conclusion

During the preliminary design, efforts have been made to mitigate, minimise, and prevent any fire hazard on site by incorporating specific design factors as described in this document. During detailed design and following battery product selection, a project specific fire risk appraisal will be used to verify the strategy presented in this document and an emergency response plan will be developed through liaison with the local fire service.

Appendix A Preliminary Site Layout Drawing




Figure 1 - General Site Layout




Figure 2: Site Wind Frequency Rose

Appendix B - RES BESS safety best practice principles

Appendix C - NFCC Recommendations Cross-Referenced to the BESS Layout and Design

Criterion	NFCC Recommendation	Status	Design Compliance with NFCC 2022	Design Compliance with Draft NFCC 2024
1	Access - Minimum of two separate access points to the site	Compliant	<p>The site has two distinct access points connected to Skreen Road. The primary site access is located approximately 335m ESE of the proposed BESS compound, while the secondary access is situated approximately 360m SE of the compound.</p> <p>Available wind data indicates that the prevailing wind direction for the area is from the southwest. Given the relative distances between the proposed BESS compound and the site entrances, as well as the prevailing wind direction, it is assessed as unlikely that both site access points will simultaneously experience obscuration due to adverse conditions at the same time.</p> <p>For further details, refer to Figure 2: Site Wind Frequency Rose, which illustrates the wind rose for the area, providing a graphical representation of the prevailing wind patterns.</p>	No change - layout remains compliant
2	Roads/hard standing capable of accommodating fire service vehicles in all weather conditions. As such there should be not extreme grades.	Compliant	<p>The proposed access tracks connecting the site entrances to the public road have been designed with a typical width of approximately 4.5m, incorporating wider sections at bends to facilitate safe vehicle manoeuvring.</p> <p>The secondary (southern) access track includes a ~220m straight section with an existing gradient of</p>	No change - layout remains compliant

			<p>approximately 6%, sloping upwards when approaching the compound. The proposed access track will be designed and constructed in line with appropriate industry guidance and in agreement with the fire and risk services to ensure an appropriate surface and gradient for the intended use.</p> <p>All site access tracks, and BESS internal compound corridors have been designed to accommodate emergency response vehicles as per Table 13.1 from Fire Safety: Approved Document B.</p>	
3	A perimeter road with passing place suitable for service vehicles	Compliant	The BESS compound layout allows access / egress routes that pass through the compound and between electrical equipment allowing access to all BESS units as indicated in Figure 1.	No change - layout remains compliant
4	Access tracks and BESS internal compound corridors must enable unobstructed access to all areas of the facility	Compliant	<p>The BESS internal compound corridors have sufficient room allowing access to all BESS units.</p> <p>The site meets requirements of Approved Document B5 Vol 2 allowing all points on site to be within 45m of a fire appliance when required.</p>	No change - layout remains compliant
5	Turning circles, passing places etc. size to be advised by FRS depending on fleet	Compliant	<p>The BESS internal compound corridors allow access to all BESS units (see Figure 1) in two different direction and allow for FRS vehicles to drive in and drive out.</p> <p>In case the FRS vehicles need to manoeuvre, the layout has allowed several possible turning points as indicated on Figure 1.</p>	No change - layout remains compliant
6	Distances from BESS units to occupied	Compliant	There are no premises within 25m of BESS units, the nearest residential dwelling is more than 300m away.	Initial min. distance to boundary remains 23m - layout is not compliant if the requirement is 30m.

	buildings and site boundaries.		The site boundary is minimum 23m distance from BESS units.	
7	Access between BESS units - minimum of 6.0m suggested.	Compliant	<p>The suggested 6.0m separation is based on a 2017 Issue of the FM Global Loss and Prevention Datasheet 5-33 (footnote 9 in the NFCC Guidance). This Datasheet has been revised in July 2023 and again in Jan 2024 and it now details the following items:</p> <ul style="list-style-type: none"> For containerized LIB-ESS comprised of Lithium iron phosphate (LFP) cells, provide aisle separation of at least 5ft (1.5m) on sides that contain access panels, doors, or deflagration vents. <p>The current site layout has been developed to include adequate spacing between the battery storage enclosure (BSE) to mitigate against the risk of fire spread in the event of a fire within one BSE. The layout allows minimum distance of 3m between batteries enclosures and any other infrastructure.</p>	<p>1. Spacing distance of 6.0m removed. New spacing requirement is reduced to approx. 1m assuming that the BESS will be fire certified to UL9540A or equivalent.</p> <p>2. BESS units are not to be vertically stacked.</p> <p>The current site layout does not allow for vertical stacked BESS.</p> <p>Layout remains compliant.</p>
8	Areas within 10m of BESS units to be cleared of combustible vegetation	Compliant	There is no existing vegetation or proposed in the design within 10m of BESS units.	No change - layout remains compliant
9	Water supply	Compliant	It is intended that an onsite water supply would not be required to achieve the fire response strategy outlined in 3.1. However, if agreed as necessary in development of the Fire Risk Management Plan, a supply of 1,900 litres per minute for at least 2 hours in line with the NFCC Guidance could be achieved through the potential provision of a piped hydrant, or through provision of space allocation for water tanks. Should the assessment	<p>The current requirement is 1,900 l/min for 2 hours. The draft NFCC 2024 has a reduced requirement of 25 l/s (1500 l/m).</p> <p>Layout remains compliant.</p>

			determine that a water tank is required, provision has been made for potential water tank locations, as indicated in Figure 3.																			
10	Signage	Compliant	Signage will be positioned at the entrance to the Site, including a site layout plan and details of the key personnel.	<p>Adherence to the dangerous substances (Notification and marking of Sites) Regulations 1990 (NAMOS) should be considered where the total quantity of dangerous substances exceeds 25 tonnes.</p> <p>It is anticipated that there will not be the need to store dangerous substance on site. Should any hazardous materials stored at the BESS facility, they will be fully justified and detailed in the emergency response plan detailing the location, description, appropriate precautions and quantity.</p> <p>Layout remains compliant.</p>																		
11	Emergency Plan	Compliant	An ERP will be developed for the Site prior to construction that will be adopted during construction and operation phases.	<p>1. Identification of sensitive receptors within 1km to allow appropriate emergency planning - This has been completed as part of the Noise Baseline Assessment, the table below details the outcome</p> <table><tr><th>Receptor</th><th>Distance (m)</th><th>Direction</th></tr><tr><td>H1</td><td>1120</td><td>Northeast</td></tr><tr><td>H2</td><td>1091</td><td>East</td></tr><tr><td>H3</td><td>1128</td><td>Northeast</td></tr><tr><td>H4</td><td>476</td><td>East</td></tr><tr><td>H5</td><td>471</td><td>South</td></tr></table>	Receptor	Distance (m)	Direction	H1	1120	Northeast	H2	1091	East	H3	1128	Northeast	H4	476	East	H5	471	South
Receptor	Distance (m)	Direction																				
H1	1120	Northeast																				
H2	1091	East																				
H3	1128	Northeast																				
H4	476	East																				
H5	471	South																				

				<table><tr><td>H6</td><td>507</td><td>Southwest</td></tr><tr><td>H7</td><td>372</td><td>Southwest</td></tr><tr><td>H8</td><td>728</td><td>South</td></tr><tr><td>H9</td><td>712</td><td>Southeast</td></tr><tr><td>H10</td><td>913</td><td>Northeast</td></tr><tr><td>H11</td><td>960</td><td>Northeast</td></tr><tr><td>H12</td><td>1093</td><td>Southeast</td></tr><tr><td>H13</td><td>1217</td><td>East</td></tr></table> <p>2. A wind rose is shown with the site layout and north direction at Figure 2.</p> <p>Layout remains compliant.</p>	H6	507	Southwest	H7	372	Southwest	H8	728	South	H9	712	Southeast	H10	913	Northeast	H11	960	Northeast	H12	1093	Southeast	H13	1217	East
H6	507	Southwest																										
H7	372	Southwest																										
H8	728	South																										
H9	712	Southeast																										
H10	913	Northeast																										
H11	960	Northeast																										
H12	1093	Southeast																										
H13	1217	East																										
12	Environmental Impacts	Complaint	A comprehensive environmental assessment for the site has been undertaken and will be submitted with the planning application.	<p>1. Suitable environmental protection measures should be provided. This should include systems for containing and managing water runoff - A Flood Risk Screening and Drainage Management Plan will be submitted as part of the planning application.</p> <p>2. Sites located in flood zones should have details of flood protection or mitigation measures. A Flood Risk Screening and Drainage Management Plan has been submitted as part of the planning application. The BESS compound does not sit within flood risk areas. Although a local area of surface water flooding has been identified along the northern access</p>																								

				<p>track, if flooding were to occur, access / egress from the site could still be achieved via the southern access and the likelihood of requiring use of the northern access at the same time as a flood event is considered very low.</p> <p>Layout remains compliant.</p>
13	System design, construction, testing and decommissioning	Compliant	Testing and decommissioning information will only be available at detailed design stage. The layout is considered compliant with this item currently.	No change - layout remains compliant.
14	Deflagration Prevention and venting	Compliant	Details will be available at detailed design stage, but equipment will be in line with NFPA855 which includes requirements for explosion prevention and venting. The layout is considered compliant with this item currently.	No change - layout remains compliant.